

# COFFS HARBOUR LABORATORY

## Environmental Analysis

Page 1 of 1



DOLPHINMARINEMAGIC  
KIERANMARSHALL  
65 ORLANDO STREET  
COFFS HARBOUR NSW 2450

BATCHNUMBER: 20/2555  
No. of SAMPLES: 1  
DATE COLLECTED: 03/11/20  
DATE RECEIVED: 03/11/20  
TIME RECEIVED: 15:10  
DATE TESTING COMMENCED:  
03/11/20

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
20/2555/1	Discharge Point # 1

ANALYSIS	UNITS	20/2555/1			METHOD NO
pH	pH unit	8.6			APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	2			APHA 5210 B
Chlorine Total	mg/L	<0.05			EL11B
Total Suspended Solids	mg/L	10			APHA 2540 D
Total Nitrogen	mg/L	0.59			EL30F
Total Phosphorus	mg/L	0.50			EL18F
Faecal Coliforms	cfu/100mL	0			ELM 3

#### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 23rd Edition, 2017, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Measurement Uncertainty is available upon request.

Report Date: 9/11/20



Accredited for compliance with ISO/IEC 17025 - Testing  
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

Shane Ewart - Delegate for

B J Wadleigh  
Laboratory Manager

The results of the tests, calibrations and/or measurements included in this document are traceable to Australia